

These Listings were Last Updated on **Monday, January 14, 2002** at 8:00 PM Eastern Standard Time.

Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

ANSI/NSF STANDARD 61

Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings.](#)

INTERNATIONALE METALL
IMPRÄGNIER GMBH
INTERNATIONAL METAL IMPREGNATING
CO LTD
DAIMLERSTRASSE 10
D-40789 MONHEIM AM RHEIN
GERMANY
49 2173 9260

Plant at: MONHEIM AM RHEIN, GERMANY

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Sealants IM 3000	[1] [2] [3]	C. HOT	MLTPL

[1] Certified for a maximum surface area to volume ratio of 50 square inches per liter.

[2] Impregnation allowable on castings exhibiting a maximum leakage of 450 cc's when tested at 60 PSI air pressure.

[3] Also evaluated as material for use in Mechanical Plumbing Devices (Section 9) for applications with a maximum surface area of 50 square inches per liter.

Number of matching Manufacturers is 1

Number of matching Products is 1

Processing time was 0 seconds